

**Gelnett, Wanda B.**

---

**From:** LYSA HOLLAND [HOLLAND@EHS.PSU.EDU]  
**Sent:** Thursday, May 11, 2006 9:06 AM  
**To:** EP, RegComments  
**Cc:** MAURINE CLAVER  
**Subject:** Administration of the Storage Tank and Spill Prevention Act

I am writing in support of the proposed regulation changes to Chapter 245. These regulations are in general more protective of the environment and as such, are needed. I am particularly pleased to see the requirement for automatic pump shutoff when a leak is detected by the line leak detectors that are required for pressurized piping systems. This alone should cause a significant reduction in releases.

Lysa J. Holland  
Environmental Compliance Engineer

The Pennsylvania State University  
Environmental Health and Safety  
6K Eisenhower Parking Deck  
University Park, PA 16802  
phone (814) 865-6391  
fax (814) 863-7427

RECEIVED  
2006 MAY 17 AM 7:27  
INDEPENDENT REGULATORY  
REVIEW COMMISSION